

# Vehicle Form

2 of 3		Vehicle ID (Monthly)			Tank Size	Product Type	DATE:		
Line No.	MONTHLY	Condition Code	Date	Initials	Line No.	Monthly	Condition Code	Date	Initials
MV1	Filtration Test (Millipore) <b>JetA Only</b>				MV14	Emergency Fuel Shutoff System (Each System)			
MV2	Free Water Checks (30 PPM Fail)					Flow Rate:			
MV3	Nozzle Screen (ALL) visual Inspection					Record Overrun (Gallons)*:			
MV3a	Nozzle Screen Cleaning					Flow Rate:			
	<i>(Required for ALL with filter monitors)</i>					Record Overrun (Gallons)*:			
MV4	Signs, Labels & Placards					Flow Rate:			
MV5	Spill Kits					Record Overrun (Gallons)*:			
MV6	Fire Extinguishers					Flow Rate:			
MV7	Fuel Hose					Record Overrun (Gallons)*:			
MV8	Meter Seals					Flow Rate:			
MV9	Lift Platforms					Record Overrun (Gallons)*:			
MV10	Refueling Vehicle Tank Interiors	Use Tank Inspection/Cleaning Vehicle form			MV15	Deadman Control Systems			
MV11	Refueling Vehicle Vents & Dome Covers					Record Overrun (Gallons)*:			
MV12	Refueling Vehicle Trough Drains				<i>Note: Verify Each Device Will Completely Stop Fuel Flow Before Overrun Has Exceeded 5% of Actual Flow Rate</i>				
		% by Volume and or Gallons	Date	Initials					
MV13	FSII (additive) Dosing Verification check*				Remarks :				
	Preblended (BZ testing) % by Volume (JetA only)								
	Unblended (Injector Calibration) oz. per 100 gallons (JetA only)								
*Requires calibration of injector or verification utilizing BZ testing									

Condition Codes: S=Satisfactory, C=Comment, N/U=Not Used, N/A=Not Applicable

ATA 103-2019.1  
Retain for 12 months

